

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0065:155 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Faraday, 805 S. Maumee St., Tecumseh MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models **FireWatch 200** 13200-120 and 13200-240 fire alarm control units. Noncoded, automatic, manual, local and remote station (protected premise). Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

13200-120, 13200-240	FireWatch 200 Mainboard
13202	Alarm/Trouble Relay Board
13203	City Tie Board

RATING: 13200-120: 120 VAC, 24 VDC
13200-240: 240 VAC, 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

06-29-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager